

CHAPTER 11
CROSS CONNECTION CONTROL

Last Updated: June 15, 2026

- 1) The District shall not allow any connection to any portion of the District's water treatment or conveyance systems which may jeopardize the quality or integrity of those systems or the District's treated water. Cross connections shall not be allowed unless controlled by an approved and properly operating backflow prevention assembly.
- 2) Employees shall implement an effective District cross connection control program which meets all applicable requirements of state and federal safe drinking water statutes, rules, and regulations. The District's cross connection control program shall include at least the following elements, and compliance shall be documented on an annual basis:
 - a) This cross connection control policy shall be reviewed at least annually, and appropriate changes shall be recommended to the Board, in order to enable the District to maintain appropriate and functional authority to enforce the District's cross connection control program.
 - b) The District shall provide appropriate and effective public education or awareness materials or presentations, alone or in cooperation with the Public Utility Departments of Salt Lake City and Sandy City, and/or the District's surplus customer and conjunctive management partner, the Jordan Valley Water Conservancy District.
 - c) All District operators shall be trained as appropriate in the area of cross connection control and backflow prevention.
 - d) The District shall maintain appropriate written records of cross connection control activities.
 - e) The District shall maintain appropriate documentation of backflow prevention assembly test history and on-going enforcement activities.